

## Elaine Briere - MVLWB

---

**From:** Lynn Carter - MVLWB [lcarter@mvlwb.com]  
**Sent:** Thursday, February 25, 2010 9:28 AM  
**To:** boydw@bathurstinlet.com  
**Cc:** permits@mvlwb.com  
**Subject:** FW: Spill Contingency  
**Attachments:** Airstrip Camp Spill Contingency.doc

Hello Boyd –

We have received this Spill Contingency document. It will be filed with application MV2009X0028.

Thanks,  
Lynn

---

Lynn Carter

**Regulatory Officer**  
**Mackenzie Valley Land and Water Board**  
4910 50th Avenue  
P.O. Box 2130  
Yellowknife, NT X1A 2P6  
Ph: (867)669-0506  
Fax: (867)873-6610  
email: [lcarter@mvlwb.com](mailto:lcarter@mvlwb.com)

---

**From:** Boyd Warner [mailto:boydw@bathurstinlet.com]  
**Sent:** Tuesday, February 23, 2010 11:19 AM  
**To:** 'Anne Umpleby'  
**Subject:** Spill Contingency

Attached is the spill contingency plan for the Airstrip Camp.

Please confirm receipt.

Thanks

Boyd Warner  
President  
Bathurst Inlet Developments (1984) Ltd  
PO Box 820  
Yellowknife, NT  
X1A 2N6  
Ph 867 920 4330  
fx 867 920 4263  
[www.bathurstarctic.com](http://www.bathurstarctic.com)  
[boydw@bathurstinlet.com](mailto:boydw@bathurstinlet.com)

BATHURST INLET DEVELOPMENTS (1984) LTD  
Spill Contingency Plan

Airstrip Camp

*prepared by*  
Boyd Warner  
Bathurst Developments  
Box 820  
Yellowknife, NT  
X0E 1H0

Aug 05, 2009

<b>Area of Application:</b>	Airstrip Camp (by Sandy Lake NT)
<b>Duration of Application:</b>	This spill contingency plan will be in effect for the duration of activities at the camp site. This plan is sufficient for our present level of activities.
<b>Application of Plan:</b>	This plan applies to the abandonment and restoration of the proposed camp listed under the site.
<b>Responsibility:</b>	The Bathurst project manager is responsible for ensuring that sites and facilities are restored to the best extent possible to their natural state.
<b>Areas of Concern:</b>	<p>The areas of concern have been divided into two categories; fuel and waste. Of these categories fuel is the most significant due to its toxicity, flammability and liquidity.</p> <p>Fuel: 1) Diesel  2) Jet A Aviation Fuel  3) Propane  4) Gasoline and 100LL</p> <p>Waste: 1) Greywater  2) Blackwater  3) Combustible waste</p>

<b>Preventative Procedures:</b>	<p>Personnel will be instructed in spill avoidance, response and cleanup procedures at the safety orientation. A spill response kit will be retained the camp.</p> <p><b>Fuel:</b></p> <ul style="list-style-type: none"> <li>• Fuel will be stored at safe distances and wherever possible in natural sumps away from drainage systems and bodies of water.</li> <li>• All fuel cache storage sites will be monitored on a regular basis for possible spills or leakage.</li> <li>• Splash pans will be employed where practical around all machinery and during any fuel transfers.</li> <li>• A spill response kit will be located on site.</li> </ul> <p><b>Waste:</b></p> <ul style="list-style-type: none"> <li>• Sewage and grey water holes will be monitored to ensure sufficient capacity.</li> <li>• Combustible waste will be contained in a screened burning barred and ashes flown out at the end of the field season.</li> </ul>
---------------------------------	---

<b>Emergency Procedures:</b>	<p>In the event of a spill of any fuel or waste respond as follows:</p> <ol style="list-style-type: none"> <li>1) Try to stop or limit the extent of the spill at source.</li> <li>2) Notify the field supervisor in camp and get the spill response equipment (shovel, absorbent material, storage drums).</li> <li>3) In the case of flammable liquids, get a dry chemical fire extinguisher in the event of a fire.</li> <li>4) Distribute absorbent material on and around the spill. Dig up contaminated soil or material. Store contaminated material in drums located in a safe location for removal.</li> <li>5) Complete the attached form entitled Spill Report  Contact Bathurst General Manager 867 920 4330  Contact Spill Response (867) 920-8130 (24 hours)  Contact DIAND Water Resources (867) 975-4298</li> </ol>
------------------------------	---

### Important Contact Numbers

Facility	PHONE	Note
<b>Pollution and Spills</b>	(867) 920-8130	
<b>Boyd Warne</b>	867 920 4330	
<b>DIAND Water Resources</b>	(867) 975-4298	
Contact Spill Response	(867) 920-8130 (24 hours)	

